



2020 Annual Water Summary Report

Prepared by:

A handwritten signature in black ink, appearing to read 'Julie Friel'.

March 23 2021

Julie Friel

Date

Manager Water Treatment

Endorsed by:

A handwritten signature in black ink, appearing to read 'Michael Loken'.

March 23 2021

Michael Loken, P. Eng.

Date

Acting Director, Water/Wastewater Treatment & Compliance

Table of Contents

Introduction	3
SUMMARY	4
System Specific	6
Sudbury Drinking Water System 210001111 - Wanapitei	7
Sudbury Drinking Water System 220003537- David Street	9
Sudbury Drinking Water System 220003485 - Garson	10
Dowling Wells and Distribution System 210001665	13
Blezard Valley/Capreol Drinking Water System-210000737	16
Falconbridge Drinking Water System - 240000020	26
Onaping/Levack Drinking Water System - 220003519	28
Vermilion Distribution System - 260006789	31

Introduction

The production and delivery of potable water in Ontario is regulated by Ontario Regulation (O.Reg.) 170/03 governed by the Ministry of the Environment, Conservation and Parks (MECP) under the Safe Drinking Water Act (SDWA), 2002, S.O. 2002, c. 32.

The purpose of this summary report is to provide system owners and municipal council information to satisfy the regulatory reporting required under Schedule 22 titled *Summary Reports for Municipalities* of the O. Reg. 170/03 Drinking Water Systems.

The information within the report must cover the following topics of the previous calendar year from January 1st through to December 31st.

A list of orders that were not met, the duration and any corrective actions needed;

A brief description of the operations of the treatment systems;

Quantities and flow rates of the water supplied during the reporting period, including monthly averages and maximum daily flows and

A comparison of the quantities and flow to the rated capacities approved in the systems approval document the Municipal Drinking Water License (MDWL).

An Annual Water Quality Report, to fulfill Section 11 of Ontario Regulation 170/03, has been completed separately and details the drinking water quality of all of the CGS owned and operated drinking water systems. This annual report is available for viewing on the City of Greater Sudbury's website (<https://www.greatersudbury.ca/live/water-and-wastewater-services/projects-plans-reports-and-presentations/drinking-water-quality-reports/>) and notices were posted in local papers to inform the public and ensure access to a computer is available at any of the CGS Citizen Service Centers to for residents to view.

SUMMARY

In the 2020 calendar year the City of Greater Sudbury (CGS) operated its Drinking Water Systems without exceeding any of the limits within the Municipal Drinking Water License. Surface water plants supplying the Sudbury Drinking Water Systems (DWS) operated at less than half of permitted levels with the Wanapitei Water Treatment Plant (WTP) averaging 44% and the David Street WTP utilizing 38% of their Permits to Take Water (PTTW). Ground water systems also operated below permitted levels; Blezard Valley Capreol DWS at 33%, Falconbridge DWS at 26%, Garson DWS at 17%, Onaping at 13%, and Dowling DWS with the lowest usage at 5% of its PTTW. During this year's calculations it was noted that there was a discrepancy in the database formula which gave higher usage percentages than actually was used last year. With this information we can conclude that we currently have an adequate source water budget.

Due to the critical importance of safe, reliable drinking water and the continuing improvements made to source water protection legislation, the City of Greater Sudbury continues to invest in our water works systems to perform critical upgrades and infrastructure renewal. It should not be assumed that these upgrades are the result of any detected incidents of poor water quality, as in most cases they are completed to reduce the risk of potable water contamination as deemed necessary through mandatory compliance known as the Statutory Standard of Care. The regulation stipulates that water works owners will continually monitor water works performance, source water quality, review levels of treatment versus current standards and emerging technologies. For example, this standard of care has been demonstrated through the following projects:

1. Removal of Iron and Manganese within the Blezard Valley Capreol system

Though iron and manganese do not pose a direct health risk, they can cause some esthetically unpleasing issues to our customers at high levels of concentration. As such, the CGS is currently in the final design phase of implementing additional treatment steps to significantly reduce levels of these contaminants through additional treatment steps.

2. Addressing contaminant levels in the Garson Well Field

Tetrachloroethylene, a harmful chemical, was detected at levels below half the provincial regulated limit within two of the source water within the Garson well field. Despite the levels being lower than permissible amounts, an Environmental Assessment (EA) is currently underway to determine the water servicing strategy for Garson due to the aging infrastructure and identification of potential ground water quality issues. The EA Process has reviewed various alternatives and a preferred

approach has been identified. Major stakeholders, including the Ministry of the Environment Conservation and Parks (MECP), have been notified of the study and a public consultation forum will be held in the very near future.

The MECP is responsible for the enforcement of regulations and conducts annual, announced and unannounced inspections of all of our facilities. Inspections “grading” has given the CGS water systems a 100% rating to date. We are still waiting for the final reports pertaining to the Wanapetei WTP (and David Street WTP sections of the Sudbury DWS as well as the Blezard Valley DWS.

As per regulatory requirement, 24 adverse water quality incident (AWQI) reports have been filled according to regulated requirements. Corrective actions were taken and issues were promptly rectified and reported to the MECP as well as the Public Health Sudbury District (PHSD) unit.

The Community Lead Testing Initiative was instilled in 2007 and falls under O. Reg. 170/03, Schedule 15.1. Although there have been challenges in garnering new volunteers for the program and restrictions due to COVID-19 isolations, CGS continued to meet sampling requirements. During the course of this biannual sampling; testing at 80 residential sites, 8 commercial sites and 30 distribution sites were completed. Lead residuals within our distribution systems ranged from a minimum of non-detection (a value below 0.1) to a maximum of 0.22 against the regulated requirement of 10 parts per billion (ppb). One residential site tested above the half limit of 5 ppb and was contacted by PHSD who in turn educated the home owner on steps to follow. Seeing that our water quality has proven not to be an issue; CGS was granted relief by MECP from lead testing in residential and commercial sites from all DWS with the exception of the sections fed by the David Street and Wanapetei plants within the Sudbury DWS. These sections must continue to be sampled not due to the quality of the water but to satisfy the section of the regulation stating minimum sampling requirement correlating to population served by specific systems. The City continues to sample the distribution water in each of the DWS and has shown no detection over 10 parts per billion. The city continues to provide corrosion control to its DWS that require the chemical treatment and this program has proven its success with the low lead laboratory results.

Water quality throughout system is monitored twenty-four hours a day 365 days a year. Regular sampling schedules are followed in accordance with O. Reg. 170/03 and our Municipal Drinking Water Licenses and Permits. The treated water is fluoridated to prevent tooth decay in all of City’s systems as PHSD mandates this requirement.

System Specific

Drinking Water Services within the City of Greater Sudbury is a combination of municipally-owned/operated utilities along with the supply of purchased potable water. The City of Greater Sudbury owns and operates two surface water treatment plants along with its distribution systems, six ground water treatment well fields along with their own distribution systems and one independent distribution system conveying purchased potable water from Vale's Vermilion Water Treatment Plant.

Table 1 - Overview of the City's Water Systems

Drinking Water System	Type of Facility	Source of Water	Communities Served
Sudbury Drinking Water System - Wanapitei	Class IV Surface water conventional treatment plant and Class IV Distribution system	Wanapitei River	Sudbury, Coniston, Wanapitei, Markstay, Garson
Sudbury Drinking Water System - David	Class III Surface water Membrane Filtration Plant and Class II Distribution system	Ramsey Lake	Sudbury (West and South sections)
Sudbury Drinking Water System - Garson	Class I Wells and Class II Distribution system	Groundwater	Garson (east of Penman Dr.)
Dowling Drinking Water System	Class I Wells and Class I Distribution system	Groundwater	Dowling
Valley Drinking Water System	Class I Wells and Class II Distribution system	Groundwater	Valley East, Azilda, Chelmsford & Capreol
Falconbridge Drinking Water System	Class I Wells and Class II Distribution system	Groundwater	Falconbridge
Onaping /Levack Drinking Water System	Class I Wells and Class II Distribution system	Groundwater	Onaping & Levack
Vermilion Distribution System	Class II Distribution System	Vermilion River WTP Owned and Operated by Vale	Lively, Naughton, Whitefish, Copper Cliff, Walden Industrial Park

Sudbury Drinking Water System 210001111 - Wanapitei

The Sudbury DWS is comprised of three different water sources; the Wanapitei Water Treatment Plant (WTP), the David WTP and the Garson Well Field.

The Wanapitei WTP is a conventional surface plant located between Coniston and Wahnapiatae. Its source water is from the Wanapitei River. The plant's rated capacity is 54,000 m³/day and provides approximately sixty percent of the City of Greater Sudbury's potable water. The treatment process follows these steps:

Raw river water is screened through coarse and fine screens. Five pumps convey the raw water several kilometers to the plant for treatment.

At the plant, the raw water is initially disinfected by chlorination. The water's pH and alkalinity are controlled by the addition of lime. A flocculent chemical (Alum) is added to remove dissolved matter that is in suspension, which causes the matter to come out of solution and precipitate. Sedimentation is a separation by gravity of clarified water and sludge. The settled sludge waste is pumped to a nearby sewage lagoon for treatment and the clarified water is sent to four filters.

The filtration process is to remove smaller particles that tend not to settle. The filtration media is a mixture of silica sand and anthracite coal.

The filtered water flows into a reservoir where lime is added to adjust the final pH and alkalinity along with addition of a corrosion control chemical.


Chlorine is added at this stage to ensure final disinfection of finished water and to maintain a residual disinfectant within the distribution system.

The treated water is pumped through ultraviolet light disinfection units to provide extra inactivation of pathogens.

The treated water is pumped to the distribution system by six vertical turbine pumps and directs the water east towards the community of Markstay, west towards the community of Coniston, to the City of Greater Sudbury and the Ellis Reservoir.

Non-Compliance with Act, Regulations, Order or Approvals

None to report for 2020. Annual Flow Summary



Wanapitei WTP						
	Total Flow m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Peak Flow L/s	MDWL Maximum Flow m ³ /d	% Capacity
January	718,636	23,182	26,041	397.6	54,000	43
February	640,447	22,084	23,610	349.4	54,000	41
March	689,069	22,228	24,324	363.8	54,000	41
April	620,668	20,689	22,162	421.4	54,000	38
May	716,493	23,113	29,946	690.7	54,000	43
June	822,626	27,421	35,760	456.0	54,000	51
July	862,982	27,838	32,258	414.0	54,000	52
August	782,976	25,257	27,890	465.3	54,000	47
September	789,386	26,313	29,397	440.7	54,000	49
October	741,544	23,921	26,338	410.3	54,000	44
November	628,420	20,947	25,001	416.9	54,000	39
December	627,011	20,226	21,480	308.9	54,000	37
Total	8,640,258				AVERAGE %	44

Sudbury Drinking Water System 220003537- David Street

Part of the Sudbury DWS the David St. WTP is a membrane ultra-filtration surface water treatment plant. The plant's rated capacity is 40,000 m³/day and provides approximately forty percent of the City of Greater Sudbury's potable water.

The raw water intake is located approximately three hundred meters distance from the shores of Ramsey Lake. The treatment process follows these steps:

Raw lake water is screened through coarse screens and two strainers. The water is initially disinfected by chlorination. Four pumps direct the water to membrane tank for ultrafiltration. The filtration process removes particles 0.02 microns in size or larger. The filtered water flows into a reservoir. Chlorine is added at this stage to ensure final disinfection of finished water and to maintain a residual disinfectant within the distribution system. Fluoride is added to prevent tooth decay along with corrosion control chemical. The treated water is pumped through ultraviolet light disinfection units to provide extra inactivation of pathogens.

The treated water is pumped to the distribution system by four vertical turbine pumps and directs water to the south, west and downtown sections of the City of Greater Sudbury. Water from this plant is also used to fill the Ellis Reservoir.

Non-Compliance with Act, Regulations, Order or Approvals

In 2020 the David system had 4 AWQIs. The first incident was a fluoride test of 1.54 mg/L when drinking water quality standard is a maximum of 1.50 mg/L. The fluoride feed pump was shut off and the system was allowed to decrease on its own. The second was a low chlorine residual in the distribution system tested at 0.03 mg/L when the standard is 0.05 mg/L. Per health unit directions the system hydrants were flushed and residuals were monitored until they returned to normal operating range. The third AWQI was a sodium result of 54 mg/L which is above the standard of 20 mg/L. The site was resampled and tested as per regulations. The last incident was a pressure lower than 20psi. Hydrants in the area were flushed, bacterial samples were taken and no adverse results were present.

Annual Flow Summary

David St. WTP						
	Total Flow m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Peak Flow L/s	MDWL Maximum Flow m ³ /d	% Capacity
January	427,821	13,801	15,365	513.3	40,000	35
February	399,104	12,874	17,105	384.2	40,000	32
March	448,871	14,480	16,303	509.7	40,000	36
April	431,771	13,928	14,571	395.3	40,000	35
May	438,412	14,142	14,607	413.0	40,000	35
June	426,160	13,747	17,517	534.3	40,000	34
July	496,608	16,020	23,585	545.0	40,000	40
August	507,940	16,385	22,110	524.1	40,000	41
September	457,309	14,752	20,729	557.1	40,000	37
October	462,427	14,917	20,847	548.8	40,000	37
November	511,732	16,507	19,505	542.2	40,000	41
December	583,374	18,819	30,351	546.3	40,000	47
Total	5,591,530				AVERAGE %	38

Sudbury Drinking Water System 220003485 - Garson

The Garson water works is a groundwater system consisting of three wells, and servicing the community of Garson east of Penman Ave and O'Neil Dr East. The three wells are:

- Garson Well No. 1;
- Garson Well No. 2, and
- Garson Well No. 3.


The system includes three vertical turbine well pumps, disinfection with sodium hypochlorite and fluoride injection as mandated by PHSD. The water is directly connected to the public distribution network. The distribution network extends from Skead Road at the north to Garson-Coniston Road at the south. The pipe network is connected to the water supply from Sudbury at the intersection of Falconbridge Road and O'Neil Drive West, therefore the community is serviced from the Sudbury Distribution system West of Penman Avenue. In the event that all of the three wells were to fail, the Garson system is connected to the Sudbury Distribution System by way of a pressure valve and would have water supplied from Sudbury.

In March 2001, a hydrogeological assessment was made of each of the wells which concluded that it is unlikely that any of them are under the direct influence of surface water. The raw water was therefore found to be in general conformance with the ODWS. Notwithstanding the historical good water quality, the aquifer used in the Garson well supply has a recharge area which includes the developed area of Garson. With direction and consultation from PHSD and the MECPC, CGS committed to undertaking a groundwater monitoring program for tetrachloroethylene (TCE). Although TCE levels found during audit sampling are well below regulatory limits, the City is proactively sampling and monitoring these levels. In 2012 four monitoring wells were drilled in the area and sampling and graphing of results is completed regularly by staff to augment historical data and to ensure the safety of the water source and public. In 2017 CGS retained a consultant to provide feasibility options for treatment of TCE and the possibility of feeding this system directly from the two surface plants. We are currently in the research stage of this project and will be conducting an environmental assessment.

Non-Compliance with Act, Regulations, Order or Approvals

Garson had one AWQI in 2020. A sodium test result was 67.7 mg/L and above the standard of 20 mg/L. Another sample was taken to ensure the result and the site will be monitored as per regulatory requirements.

Annual Flow Summary



Garson Well #1						
	Well 1 Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	8,179	264	519	17.4	1,572	17
February	8,574	296	556	15.7	1,572	19
March	8,047	260	494	15.5	1,572	17
April	7,863	262	313	15.8	1,572	17
May	9,069	293	616	15.4	1,572	19
June	8,343	278	471	17.4	1,572	18
July	8,095	261	505	16.1	1,572	17
August	9,558	308	400	15.6	1,572	20
September	8,461	282	440	40.0	1,572	18
October	7,788	251	524	16.4	1,572	16
November	6,744	225	475	16.4	1,572	14
December	7,795	251	460	16.1	1,572	16
Total	98,515				AVERAGE %	17

Garson Well #2						
	Well 2 Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	27,425	885	1,017	34.9	2,981	30
February	23,409	807	1,046	33.7	2,981	27
March	29,496	951	1,413	35.3	2,981	32
April	28,221	941	1,090	33.1	2,981	32
May	28,148	908	1,411	36.3	2,981	30
June	32,860	1,095	2,394	36.3	2,981	37
July	29,772	960	1,357	36.9	2,981	32
August	29,468	951	1,132	36.4	2,981	32
September	24,887	830	1,084	34.1	2,981	28
October	23,499	758	987	32.5	2,981	25
November	23,900	797	1,034	31.8	2,981	27
December	25,625	827	1,260	32.7	2,981	28
Total	326,710				AVERAGE %	30

Garson Well #3						
	Well 3 Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	1480	48	352	30.2	3,275	1
February	1767	61	529	28.5	3,275	2
March	3142	101	689	30.5	3,275	3
April	1136	38	309	27.9	3,275	1
May	4569	147	804	28.3	3,275	5
June	5211	174	733	34.0	3,275	5
July	4436	143	564	32.0	3,275	4
August	2421	78	367	34.3	3,275	2
September	1435	48	295	28.9	3,275	1
October	1524	49	275	30.6	3,275	2
November	717	24	326	34.0	3,275	1
December	2736	88	683	30.6	3,275	3
Total	30576				AVERAGE %	3

Dowling Wells and Distribution System 210001665

The water supply source for the Dowling wells is an unconfined aquifer of sand and gravel deposits located within the Onaping river watershed. Due to the unconfined nature of the soils and the proximity to the river, the MECP has characterized the water source as potentially groundwater under the direct influence of surface water (potentially GUDI).

Studies were conducted in 2002 with the resulting submission of a GUDI study on July 1, 2002. This study was reviewed and accepted by the MECP and as a result, both wells were deemed to be GUDI with effective in situ filtration. As such, additional treatment as ultraviolet irradiation was added to enhance disinfection to comply with the treatment requirements.

The water works includes two wells, a distribution network and an elevated water storage tank.

The treatment process follows these steps:


The system includes per well site, one well pump, disinfection with chlorine gas, ultraviolet irradiation along with fluoride injection as mandated by PHSD. The distribution network in Dowling has been

relatively reliable and is not exposed to as severe frost depths as other areas of the City. Further, the elevated water storage provides a measure of security to the water system in the event of power interruptions and watermain breaks.

Non-Compliance with Act, Regulations, Order or Approvals

Dowling had two AWQIs in 2020. Sodium test results were both above the standard of 20 mg/L. Another sample was taken from each well to ensure the result and the site will be monitored as per regulatory requirements.

Annual Flow Summary



Lionel Well						
	Lionel Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	6,316	204	453	24.3	3,640	6
February	6,804	219	456	24.7	3,640	6
March	8,202	265	538	24.3	3,640	7
April	5,095	164	532	24.7	3,640	5
May	5,933	191	566	80.0	3,640	5
June	8,127	262	637	24.3	3,640	7
July	6,046	195	535	24.3	3,640	5
August	5,915	191	514	23.9	3,640	5
September	7,062	228	577	24.3	3,640	6
October	7,849	253	567	24.7	3,640	7
November	6,308	203	529	24.7	3,640	6
December	4,041	130	517	24.3	3,640	4
Total	77,698				AVERAGE %	6

Riverside Well						
	Riverside Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	3,295	106	392	34.6	3,640	3
February	2,403	78	386	34.2	3,640	2
March	1,245	40	465	33.8	3,640	1
April	5,076	164	502	34.6	3,640	4
May	5,908	191	505	35.9	3,640	5
June	4,299	139	583	33.8	3,640	4
July	6,007	194	672	33.8	3,640	5
August	6,118	197	514	33.4	3,640	5
September	7,532	243	727	34.2	3,640	7
October	5,569	180	511	34.6	3,640	5
November	3,131	101	470	34.6	3,640	3
December	5,887	190	521	33.8	3,640	5
Total	56,471				AVERAGE %	4

Blezard Valley/Capreol Drinking Water System-210000737

In 2010, the Blezard Valley and Capreol well supply systems were determined to be one single system as both of the systems are connected. As such one Municipal Drinking Water License and Works Permit has been assigned to the entire system. This report will identify the works by geographical area where appropriate.

The Blezard Valley portion of the system is a multi-well groundwater system servicing the communities of Hanmer, Blezard Valley, Val Therese, Val Caron, McCrea Heights, Azilda and Chelmsford. Eleven groundwater wells are situated throughout the Hanmer and Val Therese area. The communities are interconnected with distribution piping and the system feeds three water storage tanks located in Val Caron, Azilda and Chelmsford. This well field extends approximately 7.5 km (west to east) from Val Therese to Hanmer.

Some of the wells are located immediately adjacent to residential homes, commercial establishments and major arterial roadways. The water quality is beginning to show the effects of urbanization such as sodium residuals higher than the provincial standard. Public education sessions and bylaws have been implemented in attempts to mitigate the quality of source water.

The Blezard wells are:

- Kenneth;
- Deschenes;
- Philippe;
- Frost;
- Michelle;
- Notre Dame;
- Chenier;
- R, and;
- I

The treatment process follows these steps:

The system includes per well site, one well pump, disinfection with chlorine gas, ultraviolet irradiation along with fluoride injection as mandated by PHSD. The distribution network has been relatively reliable. It is to be noted that all the wells producing water are before the Val Caron tank. One trunk main feeds all the water production to the two other tanks.

I well has not been in use for some time. Raw water quality has shown elevated iron and manganese that compromises the esthetic quality of the water. Studies are currently being conducted on methods of removal in order to re-introduce the well into production in the future.

The Capreol Well portion of the system draws water from two wells to service the community of Capreol. The Capreol wells are:

- M, and;
- J.

The treatment process follows these steps:

The Capreol portion of the system is a multi-well groundwater system servicing the community of Capreol. They are situated on the east side of Greens Lake. Like the Dowling wells hydrogeological studies found these wells to be potentially GUDI with effective in situ filtration and as such required UV irradiation.

The system includes per well site, one vertical turbine well pump, disinfection with chlorine gas, ultraviolet irradiation, polyphosphate for corrosion control along with fluoride injection as mandated by PHSD.

Raw water quality has shown elevated iron and manganese that compromises the esthetic quality of the water. Removal of these parameters is expected to be available in 2022 as the design phase of a project to add additional treatment steps is underway.


The Blezard Valley wells can supply water through the Capreol Boosters located onsite at the wells ensuring a continued water supply to the town of Capreol in the event the two wells are unavailable.

The distribution system in Capreol was developed in conjunction with the growth of industry in the area and, as such, some of the pipe network is relatively old. The frost depths in Capreol extend to extreme depths during cold winters, which impose additional stresses on the integrity of the system. A second water main was added to the distribution system from the well as a contingency.

Non-Compliance with Act, Regulations, Order or Approvals

The Blezard Valley system had 13 AWQIs in 2020. Nine of the incidents were fluoride residuals higher than the standard of 1.50 mg/L measured while commissioning new chemical feed systems. The sites were flushed to waste and retested to ensure the fluoride residual was lowered before returning the well to production. Two of the incidents were due to pressures in the system falling below the recommended 20 psi in the distribution lines. The areas were tested for free chlorine residuals and bacterial samples were gathered. No adverse results were present. The last two were well sites that had sodium test results over the 20 mg/L standard. As per MECP and PHSD directions the sites were resampled and will be monitored.


Annual Flow Summary



"M" Well						
	M Well Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	22,259	718	1,756	29.6	3,927	18
February	23,704	765	1,754	27.5	3,927	19
March	20,329	656	1,736	32.4	3,927	17
April	7,154	231	1,703	30.2	3,927	6
May	29,192	942	1,956	29.7	3,927	24
June	8,869	286	1,797	28.1	3,927	7
July	148	5	63	30.0	3,927	0
August	8,562	276	2,057	47.8	3,927	7
September	26,855	866	1,997	40.0	3,927	22
October	36,154	1,166	1,984	32.9	3,927	30
November	33,099	1,068	2,004	34.6	3,927	27
December	26,875	867	1,990	35.6	3,927	22
Total	243,202				AVERAGE %	17

"J" Well						
	J Well Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	25,973	838	1,788	30.4	3,273	26
February	19,030	614	1,803	30.5	3,273	19
March	31,692	1,022	1,838	30.3	3,273	31
April	38,181	1,232	1,784	31.3	3,273	38
May	23,885	770	1,870	30.4	3,273	24
June	39,900	1,287	2,046	32.0	3,273	39
July	40,333	1,301	2,026	35.9	3,273	40
August	43,298	1,397	2,103	32.8	3,273	43
September	25,275	815	2,102	31.6	3,273	25
October	14,866	480	1,954	29.3	3,273	15
November	0	0	0	0.0	3,273	0
December	20,732	669	1,993	38.4	3,273	20
Total	323,166				AVERAGE %	27

Bleazard Valley Wells Annual Flows



Well "A" Deschene						
	Deschenes Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	12,396	400	680	19.6	1,798	22
February	10,670	344	564	19.6	1,798	19
March	11,721	378	723	19.6	1,798	21
April	13,047	421	727	19.9	1,798	23
May	17,613	568	995	19.9	1,798	32
June	1,514	49	844	66.1	1,798	3
July	3	0	1	0.0	1,798	0
August	20,079	648	1,477	18.6	1,798	36
September	11,705	378	842	18.3	1,798	21
October	10,980	354	1,469	18.7	1,798	20
November	24,369	812	1,530	19.5	1,798	45
December	31,416	1,013	1,482	18.6	1,798	56
Total	165,511				AVERAGE %	25

Well "B" Kenneth						
	Kenneth Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	12,772	412	882	23.4	2,288	18
February	12,935	417	808	23.4	2,288	18
March	19,223	620	1,469	23.6	2,288	27
April	22,256	718	1,960	23.9	2,288	31
May	19,322	623	1,455	24.0	2,288	27
June	27,773	896	1,952	85.0	2,288	39
July	8,688	280	1,253	23.4	2,288	12
August	13,175	425	1,405	23.6	2,288	19
September	6,384	206	1,762	23.8	2,288	9
October	7,233	233	651	23.7	2,288	10
November	14,117	455	1,502	23.5	2,288	20
December	10,311	333	1,507	23.1	2,288	15
Total	174,190				AVERAGE %	20

Well "C" Philippe						
	Philippe Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	11887	383	698	24.8	2,288	17
February	12288	396	831	25.1	2,288	17
March	15388	496	1,011	24.4	2,288	22
April	15189	490	1,284	25.1	2,288	21
May	11080	357	1,040	25.3	2,288	16
June	27298	881	1,694	24.8	2,288	38
July	28255	911	1,913	24.7	2,288	40
August	14640	472	1,156	24.6	2,288	21
September	17051	550	1,061	25.1	2,288	24
October	19008	613	1,302	25.0	2,288	27
November	16761	541	1,248	24.9	2,288	24
December	14266	460	936	24.9	2,288	20
Total	203111				AVERAGE %	24

Well "D" Frost						
	Frost Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	12,311	397	726	25.3	2,288	17
February	12,064	389	666	26.5	2,288	17
March	16,368	528	1,125	25.7	2,288	23
April	13,190	425	1,140	26.4	2,288	19
May	24,903	803	1,741	27.3	2,288	35
June	24,736	798	1,707	25.8	2,288	35
July	23,431	756	1,675	25.4	2,288	33
August	12,491	403	972	25.4	2,288	18
September	16,988	548	1,085	25.4	2,288	24
October	17,735	572	1,067	25.6	2,288	25
November	15,361	496	1,136	26.4	2,288	22
December	14,918	481	1,171	24.9	2,288	21
Total	204,495				AVERAGE %	24

Well "E" Notre Dame						
	Notre Dame Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	16,839	543	1,148	34.2	3,105	17
February	19,222	620	1,776	36.6	3,105	20
March	23,802	768	2,696	35.8	3,105	25
April	18,620	601	1,421	34.8	3,105	19
May	27,495	887	1,657	34.5	3,105	29
June	37,351	1,205	2,643	35.3	3,105	39
July	35,110	1,133	2,730	35.5	3,105	36
August	21,433	691	1,513	34.6	3,105	22
September	22,665	731	1,365	35.3	3,105	24
October	25,325	817	1,756	35.7	3,105	26
November	23,861	770	1,555	35.2	3,105	25
December	24,877	802	2,144	36.5	3,105	26
Total	296,601				AVERAGE %	26

Well "F" Linden						
	Linden Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	42788	1,380	2,981	38.5	3,269	42
February	33960	1,171	2,288	39.5	3,269	36
March	45582	1,470	2,093	38.7	3,269	45
April	64825	2,161	3,102	39.9	3,269	66
May	55964	1,805	3,103	40.4	3,269	55
June	37460	1,249	2,763	39.7	3,269	38
July	50656	1,634	3,053	38.4	3,269	50
August	44481	1,435	3,058	39.3	3,269	44
September	46881	1,563	3,082	44.1	3,269	48
October	54066	1,744	3,078	40.7	3,269	53
November	51669	1,722	3,016	40.8	3,269	53
December	56290	1,816	3,014	40.3	3,269	56
Total	584621				AVERAGE %	49

Well "G" Pharand						
	Pharand Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	14,773	477	2,064	26.3	2,290	21
February	13,907	449	1,260	26.3	2,290	20
March	9,341	301	781	26.5	2,290	13
April	12,346	398	978	26.2	2,290	17
May	20,295	655	1,347	26.7	2,290	29
June	25,108	810	1,959	26.7	2,290	35
July	18,203	587	1,455	26.5	2,290	26
August	17,363	560	1,162	26.5	2,290	24
September	14,890	480	1,058	26.6	2,290	21
October	21,352	689	1,286	26.6	2,290	30
November	15,503	500	1,330	26.5	2,290	22
December	18,163	586	1,206	26.6	2,290	26
Total	201,242				AVERAGE %	24

Well "H" Michelle						
	Michelle Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	10,835	350	953	30.1	2,290	15
February	12,446	401	674	24.8	2,290	18
March	20,507	662	1,642	24.9	2,290	29
April	13,635	440	829	85.0	2,290	19
May	18,604	600	1,154	25.1	2,290	26
June	17,994	580	1,247	25.0	2,290	25
July	16,323	527	1,359	30.3	2,290	23
August	13,204	426	1,049	27.5	2,290	19
September	13,213	426	958	61.4	2,290	19
October	27,572	889	1,939	30.5	2,290	39
November	31,931	1,030	1,980	29.9	2,290	45
December	16,650	537	1,234	30.1	2,290	23
Total	212,914				AVERAGE %	25

Well "Q" Chenier						
	Chenier Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	31483	1,016	2,161	27.9	2,333	44
February	54230	1,870	2,161	27.6	2,333	80
March	59281	1,912	2,161	28.1	2,333	82
April	29202	973	1,754	27.8	2,333	42
May	48133	1,553	2,161	27.9	2,333	67
June	59984	1,999	2,162	27.9	2,333	86
July	61335	1,979	2,162	27.6	2,333	85
August	39305	1,268	2,075	27.3	2,333	54
September	45546	1,518	2,075	27.6	2,333	65
October	40405	1,303	2,075	27.5	2,333	56
November	39557	1,319	2,075	27.5	2,333	57
December	31322	1,010	2,075	27.6	2,333	43
Total	539780				AVERAGE %	63

Well "R"						
	R Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	76,540	2,469	2,941	36.9	3,162	78
February	51,205	1,766	2,939	36.9	3,162	56
March	34,846	1,124	2,232	36.7	3,162	36
April	49,882	1,663	2,940	36.5	3,162	53
May	36,497	1,177	2,939	36.4	3,162	37
June	42,109	1,404	2,940	36.2	3,162	44
July	64,451	2,079	2,859	36.4	3,162	66
August	68,494	2,209	2,854	35.7	3,162	70
September	48,307	1,610	2,595	34.8	3,162	51
October	33,917	1,094	2,390	34.3	3,162	35
November	37,291	1,243	2,296	34.8	3,162	39
December	55,013	1,775	2,595	34.5	3,162	56
Total	598,549				AVERAGE %	52

Falconbridge Drinking Water System - 240000020

The Falconbridge well system consists of 3 drilled wells:

- Well 5;
- Well 6, and;
- Well 7.


The treatment process follows these steps:

The system includes three submersible pumps, disinfection with chlorine gas, along with polyphosphate addition for corrosion control. The wells are located north of the Sudbury Airport. Water is supplied south to the town of Falconbridge, north to the Greater Sudbury Airport reservoir and to the Nickel Rim Mine tank. The City sells water to Glencore and two industrial clients along the south transmission line and fluoridates the water, as mandated by PHSD, before it enters the Falconbridge municipal distribution system.

Non-Compliance with Act, Regulations, Order or Approvals

Falconbridge had three AWQIs in 2020. All three incidents were sodium test results over the 20 mg/L standard. The three well sites were resampled and will continue to be monitored.

Annual Flow Summary



Falconbridge						
	Well #5 Total Flow m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Peak Flow L/s	MDWL Maximum Flow m ³ /d	% Capacity
January	9,451	305	1,129	15.6	1,417	22
February	18,323	591	1,148	15.3	1,417	42
March	11,501	371	1,070	15.7	1,417	26
April	22,076	712	1,167	15.5	1,417	50
May	17,344	559	1,122	15.5	1,417	39
June	16,076	519	1,265	15.5	1,417	37
July	16,019	517	1,199	15.5	1,417	36
August	27,399	884	1,203	15.7	1,417	62
September	16,022	517	1,260	15.7	1,417	36
October	16,718	539	1,181	15.8	1,417	38
November	9,854	318	1,111	15.4	1,417	22
December	11,374	367	1,163	15.5	1,417	26
Total	192,156				AVERAGE %	36

Falconbridge						
	Well #6 Total Flow m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Peak Flow L/s	MDWL Maximum Flow m ³ /d	% Capacity
January	357	12	215	16.0	1,417	1
February	0	0	0	0.0	1,417	0

March	0	0	0	0.1	1,417	0
April	0	0	0	1.0	1,417	0
May	3,047	98	779	16.3	1,417	7
June	10,731	346	1,239	16.2	1,417	24
July	3,515	113	653	16.5	1,417	8
August	5,500	177	1,037	15.9	1,417	13
September	20,135	650	1,278	15.8	1,417	46
October	12,965	418	1,175	15.8	1,417	30
November	7,764	250	1,167	15.8	1,417	18
December	10,366	334	1,203	16.4	1,417	24
Total	74,379				AVERAGE %	14

Falconbridge						
	Well #7 Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	25009	807	1,268	16.0	1,417	57
February	14731	475	1,227	16.2	1,417	34
March	19775	638	1,154	16.6	1,417	45
April	8899	287	1,193	16.7	1,417	20
May	13520	436	1,260	16.4	1,417	31
June	8227	265	1,207	16.8	1,417	19
July	16711	539	1,255	16.8	1,417	38
August	1572	51	477	17.1	1,417	4
September	13205	426	1,367	16.7	1,417	30
October	5159	166	1,369	16.8	1,417	12
November	13443	434	1,254	16.9	1,417	31
December	11085	358	1,213	17.0	1,417	25
Total	151336				AVERAGE %	29

Onaping/Levack Drinking Water System - 220003519

The Onaping/Levack system includes three drilled wells:

- Well 3;
- Well 4, and;
- Well 5.


The treatment process follows these steps:

The system includes three pumps, disinfection with chlorine gas, sodium hydroxide for pH adjustment, polyphosphate addition for corrosion control along with fluoride injection. An elevated storage tank with re-chlorination capabilities, a Pressure Control/Booster building with stand-by power, a Pressure control facility on Fraser Crescent and the distribution piping complete the system. The City continues to monitor sodium on a monthly basis on the raw water due to high levels present in the aquifer caused by road salt as a major highway is above grade.

Non-Compliance with Act, Regulations, Order or Approvals

Onaping had one AWQI in 2020. A test result for sodium was over the 20 mg/L standard. The site was resampled and will be monitored on a monthly basis per CGS municipal drinking water licence.

Annual Flow Summary



Onaping Wells						
	Well 3 Total Flow m ³	Average Daily Flow m ³ /d	Maximum Daily Flow m ³ /d	Peak Flow L/s	MDWL Maximum Flow m ³ /d	% Capacity
January	16,159	521	1,972	36.3	5,184	10
February	15,204	490	2,157	34.8	5,184	9
March	18,926	611	2,123	34.5	5,184	12

April	15,267	492	2,179	34.9	5,184	10
May	23,217	749	2,243	35.3	5,184	14
June	24,027	775	2,435	35.3	5,184	15
July	15,056	486	2,656	35.1	5,184	9
August	20,138	650	2,727	34.5	5,184	13
September	29,804	961	2,727	36.1	5,184	19
October	17,116	552	2,109	35.0	5,184	11
November	26,130	843	2,312	35.0	5,184	16
December	21,281	686	2,233	37.9	5,184	13
Total	242,326				AVERAGE %	13

Onaping Wells						
	Well 4 Total Flow m³	Average Daily Flow m³/d	Maximum Daily Flow m³/d	Peak Flow L/s	MDWL Maximum Flow m³/d	% Capacity
January	10,718	346	1,854	30.3	5,184	7
February	13,182	425	1,950	30.5	5,184	8
March	9,358	302	2,029	30.4	5,184	6
April	14,379	464	1,984	30.7	5,184	9
May	6,589	213	2,015	30.3	5,184	4
June	14,388	464	2,281	30.5	5,184	9
July	23,377	754	2,494	30.3	5,184	15
August	21,409	691	2,392	30.0	5,184	13
September	22,339	721	2,409	30.0	5,184	14
October	13,949	450	2,230	30.1	5,184	9
November	24,459	789	2,262	30.2	5,184	15
December	21,638	698	2,062	30.2	5,184	13
Total	195,785				AVERAGE %	10

Onaping Wells						
	Well 5 Total	Average Daily Flow	Maximum Daily Flow	Peak Flow	MDWL Maximum Flow	% Capacity

	Flow m ³	m ³ /d	m ³ /d	L/s	m ³ /d	
January	27400	884	1,964	53.2	5,184	17
February	23451	756	1,912	50.7	5,184	15
March	30133	972	2,111	50.5	5,184	19
April	26874	867	2,033	49.8	5,184	17
May	34273	1,106	2,574	50.0	5,184	21
June	21101	681	2,271	51.9	5,184	13
July	35212	1,136	3,139	51.2	5,184	22
August	38671	1,247	2,944	50.4	5,184	24
September	27599	890	3,059	51.2	5,184	17
October	27801	897	2,039	48.8	5,184	17
November	12067	389	2,199	36.5	5,184	8
December	14626	472	2,151	36.8	5,184	9
Total	319209				AVERAGE %	17

Vermilion Distribution System - 260006789

The Vermillion distribution system is a standalone distribution system that receives water from a “donor” system, as the City of Greater Sudbury purchases water from Vale, the owner of the Vermillion water treatment facility. Vale has responsibility for the treatment facility and must also comply with O. Reg. 170/03. The Vale water treatment facility is not the subject of this report.

CGS owns and operates the distribution network in the communities of Copper Cliff, Lively, Naughton, Whitefish and the Atikameksheng Anishnawbe Reserve. The system also includes the Walden Water Storage Tank and Walden Metering Chamber.

Water quality throughout the distribution systems is monitored through regular sampling in accordance with O. Reg. 170/03.

Non-Compliance with Act, Regulations, Order or Approvals

None to report.